

Project Number	Project Category	School Number	School Name	Project	Est. Start Date	Est. Completion Date	A/E	Design Status %	Contractor	Const Status %	Actual Substantial Completion Date	Final Inspection/CO Date
49092 CARES	Energy	3150	New Berlin Elementary	WHHP Replacement	6/23/23	4/1/24	N/A	N/A	Quantum Mechanical	90%		
49092 CARES	Energy	3211	Southside Middle	WHHP Replacement	6/23/23	8/1/24	N/A	N/A	Cowart Air	50%		
A-10900-001	Athletics	Various	Susie E. Tolbert Elementary, Brookview Elementary, Timucuan Elementary, Merrill Road Elementary, Biltmore Elementary, Sabal Palm Elementary	Playgrounds	10/9/23	7/30/24	N/A	N/A	Playmore Recreational & Product Services	0%		
A-10950-001	Athletics	Various	Fort Caroline Middle, Fletcher High,	Beachers	10/9/23	10/30/24	N/A	N/A	Southeastern Services & Equipment, Inc	0%		
A-10951-002	Athletics	Various	Edward H. White High, First Coast Senior High, Sandalwood High	Gender Equity Projects - Sand Volleyball courts	10/9/23	7/30/24	Waltz & Moye Inc.	50%	TBD	0%		
A-10951-003	Athletics	3153	Stanton College Preparatory	Gender Equity Projects - Stanton softball field improvements - Dugout	10/9/23	7/30/24	Axel Logan and Shafer P.A.	25%	1st Choice Engineering, Construction & Development LLC	0%		
A-10951-004	Athletics	3038	Baldwin Junior Senior High	Gender Equity Projects - Softball Fieldhouse	9/1/24	7/1/25	Axel Logan and Shafer P.A.	100%	Aud & White	0%		
A-10953-001	Arts	Various	First Coast Senior High, Mandarin Middle, Loretto Elementary, Fishweir Elementary.	Replacement of Lighting and Wiring in Cafeteria, Asseby and Auditorium.	10/9/23	10/30/24	Haddad Engineering, Inc.	25%	TBD	0%		
A-10953-001	Arts	3265	First Coast Senior High	Upgrades or Replacement of Auditorium Seating	10/9/23	10/30/24	N/A	N/A	Precise Cabling Inc & Southeastern Services & Equipment, Inc	0%		
A-10953-002	Arts	Various	Douglas Anderson School of Arts, Englewood High, First Coast Senior High, Samuel W. Wolfson Senior High	Upgrades to Stage Flooring	10/9/23	10/30/24	N/A	N/A	Trident Surfacing	0%		
A-10953-004	Arts	Various	First Coast Senior High, Mandarin Middle, Loretto Elementary, Fishweir Elementary	Replacement of Sound System and Wiring in Cafeteria, Asseby and Auditorium.	10/9/23	10/30/24	Haddad Engineering, Inc.	25%	TBD	0%		
A-10954-001	Athletics	Various	FT. Caroline Middle, Stillwell Middle, Southside Middle	Middle School Tracks	10/9/23	7/30/24	N/A	N/A	TBD	0%		
A-10955-001	Athletics	Various	Alfred duPont Middle, Mayport Middle, Southside Middle and YMLA Middle	Scoreboards	10/9/23	7/30/24	G.M. Hill Engineering, Inc.	80%	AEC Electrical Contracting Inc	0%		
A-10956-001	Athletics	Various	Stanton College Preparatory, Andrew Jackson High, Riverside High, Mandarin Senior High, Westside High	Sound Systems	10/9/23	7/30/24	Haddad Engineering, Inc.	50%	TBD	0%		
A-10957-001	Athletics	Various	Stanton College Preparatory, Andrew Jackson High, Ed White High	Tennis Courts	10/9/23	7/30/24	N/A	N/A	TBD	0%		
A-10958-001	Athletics	Various	Terry Parker High, Faxon School for the Advanced Studies	Turf Fields	10/9/23	7/30/24	Waltz & Moye Inc.	100%	AstroTurf, LLC	0%		
C-10144	Athletics	3213	Arlington Middle	Removal and replacement of football scoreboard, poles and footers.	11/30/23	2/29/24	G.M. Hill Engineering, Inc.	100%	TBD	0%		
C-10723	Secure Vestibule	Various	Biltmore Elementary, Lake Shore Middle, Demelle-Cookman Junior Senior High, Andrew Robinson Elementary, Duncan U. Fletcher Senior High	Install new walls & doors with chucker to create a secured vestibule at the school main entrance to control access to the main building prior to backing in for clearance.	6/5/23	1/2/24	Various	100%	Ajax Building Corporation	100%	1/10/24	
C-90640	Portables	3268	Atlantic Coast Senior High	Phase 2 - Install additional 4 portables.	5/1/24	8/1/24	Bhide & Hall Architects P.A.	10%	TBD	0%		
C-90640	Portables	3038	Baldwin Junior Senior High	Phase 2 - Install additional 4 portables.	5/1/24	8/1/24	Bhide & Hall Architects P.A.	10%	TBD	0%		
C-91320	Playgrounds	3058	RL Brown Elementary	Playground Replacement - new playground to replace old rotting wooden structure.	1/1/24	2/1/24	N/A	N/A	Top Line	95%		
C-91620	Modernization/Addition	3238	Fort Caroline Middle	New Auditorium	10/17/22	11/30/23	LS3P Associates, LTD	100%	E. Vaughn Rivers Construction Inc.	100%	12/1/2023	
C-91710	Replacement Onsite	3096	Jean Ribault Senior High	Replacement Onsite - Jean Ribault Senior High (New 9-12)	7/1/23	7/15/25	Schenkel	100%	Gibane Building Company	3%		
C-91720	Replacement Onsite	3072	Spring Park Elementary	Replacement Onsite - Spring Park Elementary (New K-5)	7/1/22	6/15/25	RDB Design Associates	100%	Charles Perry Partners, Inc.	0%		
C-91730	Replacement Onsite	3205	Pickett Elementary	Replacement Onsite - Pickett Elementary	6/17/24	7/14/25	Bhide & Hall Architects P.A.	100%	Hiskell, Inc.	0%		
C-91740	Replacement Onsite	3242	Louis S. Sheffield Elementary	Replacement Onsite - Louis S. Sheffield Elementary (New K-5)	11/28/22	6/15/25	RDB Design Associates	100%	Perry McCall Construction Inc	0%		
C-91750	Replacement Onsite	3087	Englewood Elementary	Replacement Onsite - Englewood Elementary (New K-5)	6/17/24	7/1/25	Bhide & Hall Architects P.A.	100%	Stellar Construction	0%		
FS-3260	Remodel	3260	Mandarin Senior High	Sanvino Line and Courtyard Remodel	TBD	TBD	TBD	0%	TBD	0%		
FS-3265	Remodel	3265	First Coast Senior High	Sanvino Line and Courtyard Remodel	4/1/24	8/30/24	Kasper Architect. & Development, Inc.	30%	TBD	0%		
M-83590	Lift Stations	3279	Kernan Middle	Replacement of the existing lift station pumps and check valves and replacement of 4" to 6" waste water pipe from lift station out to JEA main line on Kernan Blvd	6/6/22	2/1/24	Matthews Design Group	100%	Favor Plumbing	95%		
M-83590	Lift Stations	3224	Samuel W. Wolfson Senior High	Remove lift station and gravity feed to LS #1 at the football field.	6/3/24	8/2/24	Matthews Design Group	100%	Favor Plumbing	0%		
M-83590	Lift Stations	3237	Sandalwood Senior High	Removal and replacement of lift station, control panel and check valves.	6/3/24	8/2/24	Matthews Design Group	100%	Favor Plumbing	0%		
M-83590	Lift Stations	3048	Thomas Jefferson Elementary	Removal and replacement of lift station, control panel and check valves.	6/3/24	8/2/24	Matthews Design Group	100%	Favor Plumbing	0%		
M-83660	Energy	3256	Landmark Middle	Replace AHUs	6/1/23	7/1/24	Haddad Engineering, Inc.	100%	Cowart Air	85%		
M-83660	Energy	3259	Mandarin Middle	Replace AHUs	TBD	TBD	Haddad Engineering, Inc.	100%	TBD	0%		
M-83660	Energy	3260	Frank H. Peterson Academy	Replace WSPH and EMCS	TBD	TBD	Wickon & Creed	100%	TBD	0%		
M-83680	Life Safety	Various	Springfield Middle, Landon Middle, Matthew Gilbert Middle, Landmark Middle, Mandarin Middle, Riverside Senior High, Samuel W. Wolfson Senior High	Stage Roof Vent Improvements at 5 Middle Schools & 2 High Schools. Scope is to provide device to open and close the existing smoke roof vents from below with a manual winch, also for maintenance & testing.	6/5/24	8/1/24	TLC Engineering	100%	CPPI	0%		
M-83810	Drainage	3211	Southside Middle	Phase 1 - Courtyard drainage improvements between buildings 1, 2 and 3. Tie in systems to existing stormwater piping.	6/1/24	8/1/24	Matthews Design Group	100%	TBD	0%		
M-83970	Fire Alarm	3116	Sadie Tillis Elementary	Replace the existing FA with new Simplex 4100ES fire alarm system including new conduit, wiring and devices. All existing devices, conduits, etc. to be demold with activation of the new system.	9/5/22	3/1/24	Haddad Engineering, Inc.	100%	WW Gay Fire Protection	95%		
M-83970	Security	3128	Susie E. Tolbert Elementary	Replace the existing security system and devices with new system to code.	TBD	TBD	Haddad Engineering, Inc.	100%	TBD	0%		
M-83970	Fire Alarm	3241	Westside Senior High	Replace school existing fire alarm system with new FA System.	4/7/23	5/1/24	Haddad Engineering, Inc.	100%	AEC Electrical Contracting Inc	35%		
M-83970	Fire Alarm	3032	Marine Science Education Center	Replace the existing FA with new Simplex 4100ES fire alarm system including new conduit, wiring and devices. All existing devices, conduits, etc. to be demold with activation of the new system.	TBD	TBD	McVeigh & Mangum	100%	TBD	0%		
M-83970	Security	3088	John Stockton Elementary	Install new security system. Existing security system devices, conduits, etc. to be demold with activation of the new system.	TBD	TBD	TLC Engineering	100%	TBD	0%		
M-83970	Fire Alarm	3254	Mayport Middle	Replace the existing FA with new Simplex 4100ES fire alarm system including new conduit, wiring and devices. All existing devices, conduits, etc. to be demold with activation of the new system.	TBD	TBD	TLC Engineering	100%	TBD	0%		
M-83970	Fire Alarm	3086	Terry Parker Senior High	Replace the existing FA with new Simplex 4100ES fire alarm system including new conduit, wiring and devices. All existing devices, conduits, etc. to be demold with activation of the new system.	TBD	TBD	TLC Engineering	100%	TBD	0%		
M-83990	Generators	3073	John Love Elementary	Replacement of the school's standby generator system including engine-generator, automatic transfer switches and propane fuel tank. Separate transfer switches shall be provided for life safety lighting/fire alarm and optional loads. Optional loads include major cafeteria refrigeration equipment and the school's telecom (MTR/ITR) electrical services.	8/1/23	8/1/25	John Searcy & Associates, Inc.	100%	AEC Electrical Contracting Inc	15%		
M-83990	Generators	3245	Crown Point Elementary	Replacement of the school's standby generator system including engine-generator, automatic transfer switches and propane fuel tank. Separate transfer switches shall be provided for life safety lighting/fire alarm and optional loads. Optional loads include major cafeteria refrigeration equipment and the school's telecom (MTR/ITR) electrical services.	8/1/23	9/30/25	McVeigh & Mangum	100%	Miles Electrical	0%		
M-83990	Generators	3064	Hogan-Spring Glen Elementary	Replacement of the school's standby generator system including engine-generator, automatic transfer switches and propane fuel tank. Separate transfer switches shall be provided for life safety lighting/fire alarm and optional loads. Optional loads include major cafeteria refrigeration equipment and the school's telecom (MTR/ITR) electrical services.	9/1/23	9/1/25	McVeigh & Mangum	100%	TBD	0%		
M-83990	Generators	3088	John Stockton Elementary	Replacement of the school's standby generator system including engine-generator, automatic transfer switches and propane fuel tank. Separate transfer switches shall be provided for life safety lighting/fire alarm and optional loads. Optional loads include major cafeteria refrigeration equipment and the school's telecom (MTR/ITR) electrical services.	9/1/24	9/30/25	McVeigh & Mangum	100%	TBD	0%		

M-83990	Generators	3246	Neptune Beach Elementary	Replacement of the school's standby generator system including engine-generator, automatic transfer switches and propane fuel tank. Separate transfer switches shall be provided for life safety lighting/fire alarm and optional loads. Optional loads include major cafeteria refrigeration equipment and the school's telecom (MTR/ITR) electrical services.	6/1/23	8/16/24	McVeigh & Mangum	100%	Precise Cabling Inc	70%	
M-83990	Generators	3093	Pinedale Elementary	Replacement of the school's standby generator system including engine-generator, automatic transfer switches and propane fuel tank. Separate transfer switches shall be provided for life safety lighting/fire alarm and optional loads. Optional loads include major cafeteria refrigeration equipment and the school's telecom (MTR/ITR) electrical services.	11/28/22	6/28/24	McVeigh & Mangum	100%	Kim's Electrical Inc	90%	
M-83990	Generators	3164	Mount Herman Exceptional Center	Replacement of the school's standby generator system including engine-generator, automatic transfer switches and propane fuel tank. Separate transfer switches shall be provided for life safety lighting/fire alarm and optional loads. Optional loads include major cafeteria refrigeration equipment and the school's telecom (MTR/ITR) electrical services.	12/1/23	9/1/25	TLC Engineering	100%	Miles Electrical	10%	
M-84310	Electrical	3247	Anchor Academy	Replacement of existing schools Main Switchgear with new.	6/1/23	8/1/24	Haddad Engineering, Inc.	100%	Miles Electrical	45%	
M-84310	Electrical	3265	First Coast Senior High	Football field lighting replacement with new Musco LED lighting fixtures and controls.	9/1/24	8/30/25	Haddad Engineering, Inc.	25%	TBD	0%	
M-84310	Electrical	3064	Hogan-Spring Glen Elementary	Replacement of existing schools Main Switchgear with new.	12/1/23	8/1/24	Haddad Engineering, Inc.	100%	Miles Electrical	10%	
M-84310	Electrical	3152	James Welton Johnson Middle	Replacement of existing schools Main Switchgear with new.	6/1/25	8/1/25	Haddad Engineering, Inc.	100%	AEC Electrical Contracting Inc	0%	
M-84310	Electrical	3237	Sandalwood Senior High	Baseball field lighting replacement with new Musco LED lighting fixtures and controls.	6/3/25	8/29/25	Haddad Engineering, Inc.	25%	TBD	0%	
M-84310	Electrical	3280	Frank H. Peterson Academy	Phase 3 - Replacing existing FPE panels, transformers and switchgear in Bldg. 1, C Wing.	2/6/23	8/15/25	John Searcy & Associates, Inc.	100%	Thompson Electric of N. FL Inc	25%	
M-84310	Electrical	3265	First Coast Senior High	The project consists of the replacement of the school's main electrical service entrance switchboard. It is a 480V, 2500A main-to-main arrangement. JEA does deliver service via two separate utility transformers. It is intended that the switchboard be replaced in place.	6/1/25	8/1/25	McVeigh & Mangum	100%	Miles Electrical	0%	
M-84310	Electrical	3265	First Coast Senior High	The project consists of the replacement of the existing theatrical lighting and controls system in the school's auditorium. All existing fixed theatrical fixtures shall be removed (we understand the school will retain the existing follow spotlights); existing power distribution to the lights (circulating to plug-in bus at catwalk, etc.) may remain for reuse/modification as is practical. The existing control system shall be replaced completely; existing wall control locations will be used for new controls for house lighting. All new DMX controlled LED fixed lighting shall be provided.	12/1/23	8/1/24	McVeigh & Mangum	100%	Precise Cabling Inc	25%	
M-84310	Electrical	3229	Jacksonville Heights Elementary	Upgrade 400A/240V/1PH electrical service to the existing portables.	6/3/24	8/1/24	McVeigh & Mangum	100%	TBD	0%	
M-84310	Electrical	3233	Lone Star Elementary	Replacement of old electrical panels and transformers in boiler room, kitchen and hallway by the restrooms.	6/3/24	8/1/24	McVeigh & Mangum	100%	TBD	0%	
M-84310	Electrical	3202	Reynolds Lane Elementary	Replacement of old electrical panels.	6/3/24	8/1/24	McVeigh & Mangum	100%	Miles Electrical	0%	
M-84310	Electrical	3033	Riverside High	Replacement of old electrical panels in the Gym building.	6/1/24	8/1/24	McVeigh & Mangum	100%	Miles Electrical	0%	
M-84310	Electrical	3083	San Jose Elementary	The project consists of the replacement of the school's main electrical service entrance switchboard and sub-switchboard. The main is a 208V, 3000A main circuit breaker switchboard with a single distribution section. The sub-switchboard is a 208V, 2000A main breaker switchboard with single distribution section. JEA's utility transformer is expected to remain as-is. It is intended that the switchboards be replaced in place.	6/1/25	8/1/25	McVeigh & Mangum	100%	Thompson Electric of N. FL Inc	0%	
M-84310	Electrical	3237	Sandalwood Senior High	The project consists of the replacement of seven existing General Electric electrical panels that have exceeded their service life. Four of the existing panels are 480/277V, 3-phase, 4-wire 1,000- or 1,200-Amp fusible distribution boards; one is a 480/277V, 3-phase, 4-wire, 100-Amp panelboard; and two are 120/208V, 100A panelboards. The distribution boards shall be replaced in place. New panelboards shall be provided to replace the existing panelboards. The existing panelboard enclosures shall remain as junction boxes for the board circuit reconections. It is anticipated that two new electrical closets will be created.	6/1/24	8/1/24	McVeigh & Mangum	100%	Miles Electrical	0%	
M-84320	Plumbing	3086	Terry Parker Senior High	Replace existing sewer lines and manholes in front of the bus loop and parking area.	6/5/24	8/1/24	C&S	100%	Favor Plumbing	0%	
M-84320	Plumbing	3207	Westside Middle	The existing campus sewer lines and manholes are constantly being work on by maintenance due to poor drainage and constant clogging because the old clay pipes either collapse and or root bound. The engineer had the existing system surveyed and camera. Recommendation is to replace the sewer pipes with new PVC and manholes.  Scope of work is to remove the existing sewer pipe and install new PVC pipe and manholes.	6/5/24	8/1/24	Eng Engineering, Inc.	100%	E. Vaughan Rivers Construction Inc.	0%	
M-84320	Plumbing	3237	Sandalwood Senior High	Remodeling 2 group restrooms.	6/5/24	8/1/24	Kasper Architect. & Development, Inc.	100%	Perry McCall Construction Inc	0%	
M-84620	Windows	3223	Duncan U. Fletcher Senior High	Replacing the existing aluminum storefront in the courtyard of building 1 with new aluminum storefront & impact glazing. The courtyard door & hardware will also be replaced to comply with life safety for egress.	6/1/24	8/1/24	Akel Logan and Shafer P.A.	100%	Perry McCall Construction Inc	0%	
M-84620	Windows	3218	San Mateo Elementary	Building 1 - replace existing windows in classroom wing with new aluminum single windows.	6/1/25	8/1/25	Akel Logan and Shafer P.A.	100%	TBD	0%	
M-84620	Windows	3025	Springfield Middle	Bldg 4 First Floor Improvements - Convert section of the building in to maintenance storage facility. Scope includes new curb cut entrance from main street to the building. Utilize existing windows to install new overhead roll-up door and upgrade building life safety to code compliance.	2/4/24	9/2/24	Akel Logan and Shafer P.A.	100%	TBD	0%	
M-84620	Windows	3208	Parkwood Heights Elementary	Replace existing windows in Bldg. 2 Student Dining with new aluminum single-hung/ fixed glass windows with impact glazing and dark grey tint. Existing clerestory windows will be removed and replaced with insulated solid Mapes panels.	6/5/24	8/1/24	Bhide & Hall Architects P.A.	100%	Allstate Construction Inc.	0%	
M-84620	Windows	3066	Alfred duPont Middle	Building 1 - Remove existing glass block, replacement material to be determined.	6/5/24	8/1/24	LS3P Associates, LTD	100%	Auld & White	0%	
M-84620	Windows	3046	Arlington Elementary	Buildings 2 and 3 - Replacing the existing windows with new aluminum single-hung windows and fixed glass, also, installing new structural steel element to provide additional structural support for the new windows. New	6/5/24	8/1/24	Pond & Company Corporation	100%	CPPI	0%	
M-86240	Energy	3241	Westside Senior High	EMCS Replacement	1/2/24	8/9/24	N/A	N/A	Certified Control Systems	0%	
M-86240	Energy	3051	Whitehouse Elementary	EMCS Replacement	10/1/23	7/1/24	N/A	N/A	Certified Control Systems	25%	

M-87540	Elevator	3262	Andrew Robinson Elementary	Elevator Modification	TBD	TBD	N/A	N/A	Mowrey Elevators	0%		
M-87540	Elevator	3265	First Coast Senior High	Elevator Modification	TBD	TBD	N/A	N/A	Mowrey Elevators	0%		
M-87540	Elevator	3256	Landmark Middle	Elevator Modification	TBD	TBD	N/A	N/A	Mowrey Elevators	0%		
M-87540	Elevator	3058	RL Brown Elementary	Elevator Modification	TBD	TBD	N/A	N/A	Mowrey Elevators	0%		
M-88380	Paving	3267	LaVilla School of the Arts	Parking Lot Addition in the NW Corner of Campus (Approximately One acre in size)	6/5/24	8/1/24	Waltz & Moye Inc.	100%	E. Vaughan Rivers Construction Inc.	0%		
M-88380	Paving	3164	Mount Herman Exceptional Center	Design: Pave and Stripe driveway, loop and West parking lot Construction will occur in Summer 2024	6/1/23	8/1/24	Waltz & Moye Inc.	100%	TBD	0%		
M-91380	ADA	3247	Anchor Academy	Modify existing ADA parking to code compliance and safe route to the building adding concrete sidewalk as necessary	6/5/24	8/1/24	Mathews Design Group	100%	TBD	0%		
M-91380	ADA	3254	Mayport Middle	Modify existing ADA parking to code compliance and safe route to the building adding concrete sidewalk as necessary	6/5/24	8/1/24	Mathews Design Group	100%	TBD	0%		
M-91380	ADA	3116	Sadie Tillis Elementary	Modify existing ADA parking to code compliance and safe route to the building adding concrete sidewalk as necessary	6/5/24	8/1/24	Mathews Design Group	100%	TBD	0%		
P-83800	Roofing	3090	Englewood Senior High	Roof Replacement	6/1/24	12/1/24	Kasper Architect. & Development, Inc.	100%	TBD	0%		
P-83800	Roofing	3211	Southside Middle	Roof Replacement	3/1/24	9/1/24	Kasper Architect. & Development, Inc.	100%	BBG Contracting Group	0%		
P-83800	Roofing	3153	Stanton College Preparatory	Roof Replacement	6/1/24	12/1/24	Kasper Architect. & Development, Inc.	70%	TBD	0%		
P-8950011	Security & Safety Upgrade	Various	Sandalwood Senior High, Brookview Elementary, Greenfield Elementary, Alfred I. Dupont Middle, Southside Middle, Alden Rd EC	Security & Safety - Ph2 Gr1 for Sandalwood Senior High, Brookview Elementary, Greenfield Elementary, Alfred I. Dupont Middle, Southside Middle, Alden Rd EC	3/1/22	2/27/24	Kasper Architect. & Development, Inc.	100%	Scherer Construction	90%		
P-8950018	Security & Safety Upgrade	Various	Chimney Lakes Elementary, Enterprise Learning Academy, Mamie Agnes Jones Elementary, Chaffee Trail Elementary, Westview K-8	Security & Safety - Ph2 Gr8 (Chimney Lakes Elementary, Enterprise Learning Academy, Mamie Agnes Jones Elementary, Chaffee Trail Elementary, Westview K-8)	2/3/22	5/1/24	Bhide & Hall Architects P.A.	100%	Rivers Constructors	5%		
P-8950020	Security & Safety Upgrade	Various	A. Philip Randolph High, John E. Ford Elementary, Bridge to Success Middle, Northwestern Legends Elementary, Stanton High	Security & Safety - Ph3 Gr2 (A. Philip Randolph High, John E. Ford Elementary, Bridge to Success Middle, Northwestern Legends Elementary, Stanton High)	12/29/22	5/1/24	LSPP Associates, LTD	100%	Foresight Construction	10%		
P-8950021	Security & Safety Upgrade	Various	Andrew Jackson High, Dinsmore Elementary, Jean Ribault Middle, Long Branch Elementary, North Shore Elementary	Security & Safety - Ph3 Gr3 (Andrew Jackson High, Dinsmore Elementary, Jean Ribault Middle, Long Branch Elementary, North Shore Elementary)	6/15/22	5/1/24	Bhide & Hall Architects P.A.	100%	Haskell, Inc.	0%		
P-8951003	Renovation/Addition	3223	Duncan U. Fletcher Senior High	Renovation/Addition - Duncan U. Fletcher Senior High	7/21/22	6/24/24	Kasper Architect. & Development, Inc.	100%	Cubepiper Construction	1%		
P-8951004	Renovation/Addition	3260	Mandarin Senior High	Renovation/Addition - Mandarin Senior High	10/20/23	6/30/25	Harvard Jolly Architecture	100%	Batson-Cook Company	0%		
P-8951005	Renovation/Addition	3207	Westside Middle	Renovation/Addition - Westside Middle	8/18/22	8/5/24	Altman + Barnett	100%	Stellar Construction	35%		
P-8951006	Modernization/Addition	3030	Loretto Elementary	Modernization/Addition	8/18/22	8/1/25	R. Dean Scott	33%	Auld & White	0%		
P-8951007	Renovation	3058	Richard L. Brown Gifted & Talented	Renovation - R.L. Brown	10/20/23	7/2/25	PQH Group	100%	Auld & White	0%		
P-91660	Replacement Onsite	3076	Southside Estates Elementary (New K-5)	Replace On-Site - Southside Estates Elementary (New K-5)	3/1/22	7/1/24	RDB Design Associates	100%	Haskell, Inc.	40%		
P-91670	Replacement Onsite	3099	Highlands Elementary (New K-5)	Replace On-Site - Highlands Elementary (New K-5)	3/1/22	7/15/24	Zyscovich Inc.	100%	Charles Perry Partners, Inc.	55%		
P-91680	Replacement Onsite	3140	Chaffee Trail Middle	New Construction - Chaffee Trail Middle (New 6-8 Green Site)	2/1/22	7/15/24	Zyscovich Inc.	100%	Gilbane Building Company	40%		
P-91690	Deferred Maintenance	3070	North Shore Elementary	Deferred Maintenance - North Shore Elementary	4/15/23	9/9/24	Kasper Architect. & Development, Inc.	100%	Allstate Construction Inc.	10%		
TP-99740-3002	Technology	3002	Team Center A	Central Monitoring Station	TBD	TBD	Haddad Engineering, Inc.	50%	TBD	0%		
TP-99740-3002B-PRC	Technology	3002B	Team Center B	First Floor Renovations at Bldg. B	9/1/23	7/1/24	Pond & Company Corporation	100%	Auld & White	0%		
TP-998*	Technology	Various	Various	500 Classroom AV	7/1/21	6/1/24	Haddad Engineering, Inc.	100%	Allstate Construction Inc.	50%		